

CERTIFICATE OF COMPLIANCE

Certificate Number 20181205-E482978
Report Reference E482978-20181129
Issue Date 2018-DECEMBER-05

Issued to: Pioneer Metal Company W.L.L.
P.O.Box 491,
Doha, Qatar QATAR

This certificate confirms that
representative samples of CABLE TRAYS, METAL
USC - Ventilated Heavy Duty Cable Tray.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/NFPA 70, "National Electrical Code" (NEC), as to
their suitability for use as equipment grounding conductors
in accordance with Sections 392.60(A) and 392.60(B) of the
of NFPA 70 NATIONAL ELECTRICAL CODE WITH AMD 1
- 5 and NEMA VE 1, Metal Cable Tray Systems

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and
covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181205-E482978
Report Reference E482978-20181130
Issue Date 2018-DECEMBER-05

Issued to: Pioneer Metal Company W.L.L
P.O.Box 491,
Doha, Qatar QATAR

This certificate confirms that
representative samples of CABLE TRAYS, METAL
USC - Steel Ladder Cable Trays, Cable Ladder Fittings,
and Cable Ladder Connectors

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/NFPA 70, "National Electrical Code" (NEC), as to
their suitability for use as equipment grounding conductors
in accordance with Sections 392.60(A) and 392.60(B) of the
of NFPA 70 NATIONAL ELECTRICAL CODE WITH AMD 1
- 5 and NEMA VE 1, Metal Cable Tray Systems

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and
covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181205-E482978
Report Reference E482978-20181201
Issue Date 2018-DECEMBER-05

Issued to: Pioneer Metal Company W.L.L
P.O.Box 491,
Doha, Qatar QATAR

This certificate confirms that representative samples of CABLE TRAYS, METAL USC - Galvanized Solid Bottom Channel Cable Tray, Trunking, Trunking Fittings, Connectors, Covers.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/NFPA 70, "National Electrical Code" (NEC), as to their suitability for use as equipment grounding conductors in accordance with Sections 392.60(A) and 392.60(B) of the NEC

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

